



Florida Energy Efficient Code
House Infiltration Test- Prescriptive & Performance Method

FRANKLIN COUNTY BUILDING DEPARTMENT

34 Forbes Street, Suite 1, Apalachicola, Florida 32320

Phone: 850-653-9783 Fax: 850-653-9799

http://www.franklincountyflorida.com/planning_building.aspx

EFFECTIVE DATE:
JULY 1, 2017

PERMIT #

APPLICATION MUST BE COMPLETE:

Property Owner/s: _____

Contact Information: Home #: _____ Cell #: _____

Mailing Address: _____ City/State/Zip: _____

EMAIL Address: _____

Contractor Name: _____ Business Name: _____

Contact Information: Office #: _____ Cell #: _____

State License #: _____ County Registration #: _____

Mailing Address: _____ City/State/Zip: _____

EMAIL Address: _____

PROPERTY DESCRIPTION: 911 Address: _____

Lot/s: _____ Block: _____ Subdivision: _____ Unit: _____

Parcel Identification #: _____

JURISDICTION: Franklin County City of Carrabelle
 Apalachicola Eastpoint St. George Island Carrabelle Dog Island Lanark/ St. James St. Teresa Alligator Point

Florida Energy Efficient Code: House Infiltration Test- Prescriptive & Performance Method

R402.1.2 Testing: The building of dwelling unit shall be tested and verified as having an air leakage rate of not exceeding 5 air changes per hour in Climate Zones 1 and 2, 3 air changes per hour in Climates Zones 3 through 8. Testing shall be conducted with a blower door at a pressure or 0.2 inches w.g. (50 Pascals). Where required by the code official, testing shall be conducted by an approved third party. A written record of the results of the test shall be signed by the party including and provided to the code official. Testing shall be performed at any time after creation of all penetration of the building thermal envelope.

HOUSE INFILTRATION TEST RESULTS

CFM (50) = _____ VOLUME = _____ ACH (50) = (CFM (50) x 60/ VOLUME = _____

PASS **FAIL**

PASSING RESULT MUST BE 7 ACH.

AUTHORIZED THIRD PARTY

I, here by certify that the above House Infiltration results demonstrate compliance with Florida Energy Code requirements in accordance with Section R402.1.2

SIGNATURE

DATE

LICENSE NUMBER

PRINTED NAME